

<b>PROJECT NAME:</b>	Newcastle Hospital – Upgrade and Maintenance of various buildings Phase 2: (Package C) Perimeters fence, Perimeter lighting, Roof coverings, Medical waste, etc.
<b>BID NO:</b>	ZNTL 04018W
<b>CLOSING DATE:</b>	6 October 2020
<b>ISSUE DATE OF CLARIFICATION</b>	23 September 2020

**BID CLARIFICATION FOR THE NEWCASTLE PACKAGE C TENDER ADVERTISED ON 4 SEPTEMBER 2020**

ITEM	QUERIES	ANSWER
1	Functionality – proof of working capital – please note that bank statements are confidential documents and by company policy we are unable to provide this for the tender. Please confirm if a letter from the bank confirming that we have access	Please note that you are advised to comply with the tender conditions listed in the tender document so that your tender would be able to compete with others
2	Functionality – Letters of credit reference – please advise if we are to have a credit limit of R2 Million with each supplier or in total	The credit limit from each supplier must be R2 Million or more
3	COVID – 19 Related cost	<b><i>See Addendum1 attached</i></b>
4	Please assist with the drawings for Joinery fittings	<b><i>See attached</i></b>
5	Please assist with drawings for the air-conditioner	Items for the cold room are measured in the boq, tenderers to price the individual components Items 14/358 to 27/360
6	Please assist with an excel copy of the boq	<b><i>See attached</i></b>
7	Kindly assist with the following DB size in question: Electrical (Page 66 item 12, Preamble)	<u>Page 66: Stage 1</u>  The dimensions of the DB's are not critical and do not have to fit inside an existing cabinet.  However, the DB's are surface mounted complete with Doors, covers, hinges, pad-lockable latch etc. and switchgear as specified.
8	Kindly assist with the following DB size in question: Electrical (Page 349 item 1, Preamble)	<u>Page 349: Medical Waste</u>  <b>DB 1.1</b> is a new Flush mounted Distribution board complete with Doors, covers, hinges, pad-lockable latch etc. and switchgear as specified.  <b>DB 1.2</b> is a new surface mounted IP55 panel complete with Doors, covers, hinges, pad-lockable latch etc. and switchgear as specified.
9	Drawings needed as stated in BOQ - Edge and corner protectors (Page 307 items 9-11)	<b><i>See attached</i></b>